

\$800 Installed

Versa-Ped Service Pedestals


U5701 Series



MILBANK®



ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	1113750	POST ASSY
2	1	1047062	GASKET
3	1	(SEE CHART)	200A RL POWER HEAD
4	4	1046977	SCREW 1/4-20 x 1/2
5	3	1114067	250 kcmil AL WIRE
6	1	1113751	FRONT, BLANK
7	2	1125023	RIVET .188 X .437
8	1	(SEE CHART)	UQFPH CIRCUIT BREAKER
9	2	1106458	JUMPER BUS
10	4	1002762	SCREW, HX. HD W/ BELL
11	1	1109887	INSULATOR
12	3	1028184	PLASTIC PLUG
13	1	1025144	LABEL, U/L
14	1	1025109	LABEL, CIRCUIT BREAKER
15	1	1000158	WIREMAN PAD



NOTES:

- 1.) AFFIX GASKET AROUND OPENING IN POST BEFORE JOINING UNITS.
- 2.) FOR FIELD INSTALLED STABILIZER FOOT ORDER KIT #K5415
- 3.) FOR RECEIPTABLE KITS SEE DRAWING #5136-21.
- 4.) FOR FIELD CONVERTING FORM PARALLEL WIRED TO SERIES WIRED ORDER KIT #K5194.
- 5.) LABEL #1025109 LOCATION ABOVE UQF C/B ON D/F

SUFFIX (AMP/P)	BREAKER #
---	NONE
100P	1007859
125P	1124944
150P	1124945
200P	1090070

CATALOG SUFFIX	POWER HEAD
NONE	1113895
-BL	1113896
-5T6	1113897
-5T9	1113898

General Offices: Kansas City, MO Title: 200A-4T RGLS PEDestal W/LEVER BYPASS PARALLEL WIRED	
Material:	
Shear/ Die#:	
Finish:	MILBANK LIGHT GRAY
Part Wt.:	
Tolerances:	Third Angle
Uxxx Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X- ±.2	
BY:	
D.F. Scale:	NTS
D.F. Drawn By:	MAS
Checked By:	
Approved By:	
Catalog No.:	U5701-O-(AMP/P)
Customer:	
Drawing No.:	5701
Date:	6-16-04
Sheet:	1 of 1

CARTON #XXXXXXXX

REV	DATE	DESCRIPTION
**		
A	8/24/06	NEW PDR #12331
B	3/14/07	1125023 WAS 104746 (ECO #15006) CHART: 1007859 WAS 1047675; 1124944 WAS 1007853; 1124945 WAS 1047684; 1090070 WAS 1047691; REM 22 COLUMN (ECO #13719)

VERSA-PED

ACCESSORIES

STANDARD FEATURES

